

TEST ATTESTATION

Contract No.: 475/2009/1 - FT 04.05.2009
RO/sta
ZVR-850936522

Customer: KABA GmbH
Ulrich-Bremi-Straße 2
A-3130 Herzogenburg

Subject: Extension of validity of the test attestation 1408/2005/1 of the test of cylinders for locks type Gege pExtra 5-pin according to ÖNORM EN 1303, dated: April 2005 and ÖNORM B 5351, dated: November 2003

Result: According to test report No. 1408/2005 Holzforschung Austria confirms, that the cylinder for locks type pExtra 5-pin fulfills the requirements of ÖNORM EN 1303, ÖNORM B 5356 and ÖNORM B 5351 clause 4.2, 5.2 and 6.3 class W_Z 3.

Classification to EN 1303:

Category of use:	1
Test cycles / Durability	6
Door mass	-
Fire resistance	1
Safety	-
Corrosion resistance and temperature	C
Key related security	4
Attack resistance	2 ¹⁾


¹⁾ Attack resistance class 2 only in combination with suitable security furniture resp. rosette and cylinder extraction protection.

Period of validity: As a result of the publication of this test attestation the above mentioned test report remains valid as long as no modifications are implemented.



DI M. Wieser
Authorised signatory

HOLZFORSCHUNG AUSTRIA

R. Oberressl
Technical consultant

In case of dispute the original German version prevails. This translation is for information purposes only.

Accredited for testing and inspection by the Austrian Federal Ministry for Economics and Labour and the Austrian Institute of Construction-Engineering OIB-190-004/98-008